




ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

AW 40 EVI



55 °C

35 °C



54 dB



72 dB

■ 41	■ 40
■ 47	■ 47
■ 58	■ 58
kW	kW



2015

811/2013

AW 40 EVI

ErP Data

	55 °C	35 °C
Energy class	A+	A++
η [%]	121	154
P_{rated} [kW]	47	47
Q_{HE} [kWh/y]	27480	21587
SCOP [-]	3.02	3.84
$T_{bivalent}$ [°C]	-7	-7

	A	A++
Energy class	A	A++
η [%]	96	137
P_{rated} [kW]	41	40
Q_{HE} [kWh/y]	41400	29098
SCOP [-]	2.40	3.42
$T_{bivalent}$ [°C]	-7	-7

	A++	A++
Energy class	A++	A++
η [%]	184	184
P_{rated} [kW]	58	58
Q_{HE} [kWh/y]	11601	11581
SCOP [-]	4.59	4.60
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓