



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

AW 47 EVI



55 °C


35 °C



54 dB



76 dB



2015

811/2013

AW 47 EVI

ErP Data

	55 °C	35 °C
Energy class	A+	A++
η [%]	121	154
P_{rated} [kW]	55	55
Q_{HE} [kWh/y]	32036	25167
SCOP [-]	3.02	3.84
$T_{bivalent}$ [°C]	-7	-6

	A	A++
Energy class	A	A++
η [%]	96	137
P_{rated} [kW]	48	47
Q_{HE} [kWh/y]	48265	33923
SCOP [-]	2.40	3.42
$T_{bivalent}$ [°C]	-7	-6

	A++	A++
Energy class	A++	A++
η [%]	184	184
P_{rated} [kW]	68	68
Q_{HE} [kWh/y]	13524	13501
SCOP [-]	4.60	4.60
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓