




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

AW 47 EVI



55 °C

35 °C



54 dB



76 dB

■ 48	■ 47
■ 55	■ 55
■ 68	■ 68
kW	kW



2015

811/2013

**AW 47 EVI**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A+</b>	<b>A++</b>
$\eta$ [%]	121	154
$P_{rated}$ [kW]	55	55
$Q_{HE}$ [kWh/y]	32036	25167
SCOP [-]	3.02	3.84
$T_{bivalent}$ [°C]	-7	-6

	A	A++
Energy class	<b>A</b>	<b>A++</b>
$\eta$ [%]	96	137
$P_{rated}$ [kW]	48	47
$Q_{HE}$ [kWh/y]	48265	33923
SCOP [-]	2.40	3.42
$T_{bivalent}$ [°C]	-7	-6

	A++	A++
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	184	184
$P_{rated}$ [kW]	68	68
$Q_{HE}$ [kWh/y]	13524	13501
SCOP [-]	4.60	4.60
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓