




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TWWi 75



55 °C

35 °C



**A++**

**A++**



58 dB



- dB

■ 65  
■ **65**  
■ 65  
kW

■ 75  
■ **75**  
■ 75  
kW



2015

811/2013

**TWWi 75**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	180	235
$P_{rated}$ [kW]	65	75
$Q_{HE}$ [kWh/y]	34189	26118
SCOP [-]	4.49	5.87
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	157	232
$P_{rated}$ [kW]	65	75
$Q_{HE}$ [kWh/y]	46804	31589
SCOP [-]	3.92	5.81
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	233	234
$P_{rated}$ [kW]	65	75
$Q_{HE}$ [kWh/y]	16934	16890
SCOP [-]	5.83	5.84
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓