



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

TWW 90 SHR



55 °C

35 °C



A++

A++



55 dB



- dB

■ 39
■ **39**
■ 39
kW

■ 44
■ **44**
■ 44
kW



2015

811/2013

TWW 90 SHR

ErP Data

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 179 | 234 |
| P_{rated} [kW] | 39 | 44 |
| Q_{HE} [kWh/y] | 20266 | 15482 |
| SCOP [-] | 4.47 | 5.84 |
| $T_{bivalent}$ [°C] | -7 | -10 |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 157 | 232 |
| P_{rated} [kW] | 39 | 44 |
| Q_{HE} [kWh/y] | 27744 | 18725 |
| SCOP [-] | 3.92 | 5.80 |
| $T_{bivalent}$ [°C] | -7 | -10 |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 232 | 232 |
| P_{rated} [kW] | 39 | 44 |
| Q_{HE} [kWh/y] | 10038 | 10012 |
| SCOP [-] | 5.79 | 5.81 |
| $T_{bivalent}$ [°C] | - | - |

CONTROLLER



| | | |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |