




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TWW 100



55 °C

35 °C



**A++**

**A++**



**57** dB



- dB

■ 90  
■ **90**  
■ 90  
kW

■ 103  
■ **103**  
■ 103  
kW



2015

811/2013

**TWW 100**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	180	235
$P_{rated}$ [kW]	90	103
$Q_{HE}$ [kWh/y]	47021	35921
SCOP [-]	4.49	5.87
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	157	232
$P_{rated}$ [kW]	90	103
$Q_{HE}$ [kWh/y]	64371	43445
SCOP [-]	3.93	5.81
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	234	234
$P_{rated}$ [kW]	90	103
$Q_{HE}$ [kWh/y]	23290	23229
SCOP [-]	5.84	5.86
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓