




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

WW 46 EVI



55 °C

35 °C



**A++**

**A++**



51 dB



- dB

41  
**41**  
41  
kW

46  
**46**  
46  
kW



2015

811/2013

**WW 46 EVI**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	179	234
$P_{rated}$ [kW]	41	46
$Q_{HE}$ [kWh/y]	21265	16245
SCOP [-]	4.47	5.84
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	157	232
$P_{rated}$ [kW]	41	46
$Q_{HE}$ [kWh/y]	29112	19648
SCOP [-]	3.92	5.81
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	232	232
$P_{rated}$ [kW]	41	46
$Q_{HE}$ [kWh/y]	10532	10505
SCOP [-]	5.79	5.81
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓