



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

WW 53 EVI



55 °C

35 °C



A++

A++



53 dB



- dB

■ 47
■ **47**
■ 47
kW

■ 53
■ **53**
■ 53
kW



2015

811/2013

WW 53 EVI

ErP Data

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 179 | 234 |
| P_{rated} [kW] | 47 | 53 |
| Q_{HE} [kWh/y] | 24381 | 18626 |
| SCOP [-] | 4.48 | 5.85 |
| $T_{bivalent}$ [°C] | -7 | -10 |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 157 | 232 |
| P_{rated} [kW] | 47 | 53 |
| Q_{HE} [kWh/y] | 33378 | 22527 |
| SCOP [-] | 3.92 | 5.81 |
| $T_{bivalent}$ [°C] | -7 | -10 |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 232 | 233 |
| P_{rated} [kW] | 47 | 53 |
| Q_{HE} [kWh/y] | 12076 | 12045 |
| SCOP [-] | 5.81 | 5.82 |
| $T_{bivalent}$ [°C] | - | - |

CONTROLLER



| | | |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |