



ENERG Y IJA
енергия - ενεργεια IE IA

WW 07







55 °C

A++

35 °C

A++






43 dB


■ 6 ■ 7

■ **6** ■ **7**

■ 6 ■ 7

kW kW





- dB

2015

811/2013

WW 07

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	177	229
P_{rated} [kW]	6	7
Q_{HE} [kWh/y]	3003	2292
SCOP [-]	4.43	5.72
$T_{bivalent}$ [°C]	-10	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	160	236
P_{rated} [kW]	6	7
Q_{HE} [kWh/y]	4112	2774
SCOP [-]	4.01	5.90
$T_{bivalent}$ [°C]	-10	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	219	220
P_{rated} [kW]	6	7
Q_{HE} [kWh/y]	1487	1483
SCOP [-]	5.48	5.49
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓