



# ENERG

енергия - ενεργεια

Y IJA
IE IA



## WW 11





55 °C

**A++**

35 °C

**A++**






**43** dB

■ 9    ■ 11

■ **9**    ■ **11**

■ 9    ■ 11

kW    kW



2015
811/2013

### WW 11

### ErP Data

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	180	234
$P_{rated}$ [kW]	9	11
$Q_{HE}$ [kWh/y]	4658	3556
SCOP [-]	4.51	5.85
$T_{bivalent}$ [°C]	-9	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	161	238
$P_{rated}$ [kW]	9	11
$Q_{HE}$ [kWh/y]	6378	4302
SCOP [-]	4.02	5.94
$T_{bivalent}$ [°C]	-9	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	227	228
$P_{rated}$ [kW]	9	11
$Q_{HE}$ [kWh/y]	2305	2299
SCOP [-]	5.68	5.69
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓