



**ENERG** Y IJA  
енергия - ενεργεια IE IA

WW 14







55 °C

**A++**

35 °C

**A++**






**44 dB**

■ 12    ■ 14

■ **12**    ■ **14**

■ 12    ■ 14

kW    kW



2015

811/2013

## WW 14

## ErP Data

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	179	233
$P_{rated}$ [kW]	12	14
$Q_{HE}$ [kWh/y]	6356	4854
SCOP [-]	4.47	5.82
$T_{bivalent}$ [°C]	-8	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	159	235
$P_{rated}$ [kW]	12	14
$Q_{HE}$ [kWh/y]	8704	5873
SCOP [-]	3.97	5.87
$T_{bivalent}$ [°C]	-8	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	228	228
$P_{rated}$ [kW]	12	14
$Q_{HE}$ [kWh/y]	3147	3139
SCOP [-]	5.69	5.70
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓