



ENERG Y IJA
енергия - ενεργεια IE IA

WW 14







55 °C

A++

35 °C

A++






44 dB

■ 12 ■ 14

■ **12** ■ **14**

■ 12 ■ 14

kW kW



2015

811/2013

WW 14

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	179	233
P_{rated} [kW]	12	14
Q_{HE} [kWh/y]	6356	4854
SCOP [-]	4.47	5.82
$T_{bivalent}$ [°C]	-8	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	159	235
P_{rated} [kW]	12	14
Q_{HE} [kWh/y]	8704	5873
SCOP [-]	3.97	5.87
$T_{bivalent}$ [°C]	-8	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	228	228
P_{rated} [kW]	12	14
Q_{HE} [kWh/y]	3147	3139
SCOP [-]	5.69	5.70
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓