


ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK BW 05



| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 128 | 168 |
| P_{rated} [kW] | 5 | 5 |
| Q_{HE} [kWh/y] | 2992 | 2236 |
| SCOP [-] | 3.20 | 4.21 |
| $T_{bivalent}$ [°C] | - | - |


| | 55 °C | 35 °C |
|---------------------|-----------|------------|
| Energy class | A+ | A++ |
| η [%] | 114 | 175 |
| P_{rated} [kW] | 5 | 5 |
| Q_{HE} [kWh/y] | 4145 | 2694 |
| SCOP [-] | 2.86 | 4.37 |
| $T_{bivalent}$ [°C] | - | - |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 162 | 162 |
| P_{rated} [kW] | 5 | 5 |
| Q_{HE} [kWh/y] | 1449 | 1446 |
| SCOP [-] | 4.04 | 4.04 |
| $T_{bivalent}$ [°C] | - | - |

42 dB

- dB

5 kW 5 kW



2015 811/2013

BW 05

ErP Data

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 128 | 168 |
| P_{rated} [kW] | 5 | 5 |
| Q_{HE} [kWh/y] | 2992 | 2236 |
| SCOP [-] | 3.20 | 4.21 |
| $T_{bivalent}$ [°C] | - | - |

| | 55 °C | 35 °C |
|---------------------|-----------|------------|
| Energy class | A+ | A++ |
| η [%] | 114 | 175 |
| P_{rated} [kW] | 5 | 5 |
| Q_{HE} [kWh/y] | 4145 | 2694 |
| SCOP [-] | 2.86 | 4.37 |
| $T_{bivalent}$ [°C] | - | - |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 162 | 162 |
| P_{rated} [kW] | 5 | 5 |
| Q_{HE} [kWh/y] | 1449 | 1446 |
| SCOP [-] | 4.04 | 4.04 |
| $T_{bivalent}$ [°C] | - | - |

CONTROLLER



| | | |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |