

 **ENERG** Y IJA  
енергия - ενεργεια IE IA


**WAMAK** BW 05

 55 °C 35 °C


**A++** **A++**

A++  
A+  
A  
B  
C  
D  
E  
F  
G

 **42 dB**

 - dB

■ 5 ■ 5  
■ **5** ■ **5**  
■ 5 ■ 5  
kW kW



2015 811/2013

## BW 05

## ErP Data

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	128	168
$P_{\text{rated}}$ [kW]	5	5
$Q_{\text{HE}}$ [kWh/y]	2992	2236
SCOP [-]	3.20	4.21
$T_{\text{bivalent}}$ [°C]	-	-

	A+	A++
Energy class	<b>A+</b>	<b>A++</b>
$\eta$ [%]	114	175
$P_{\text{rated}}$ [kW]	5	5
$Q_{\text{HE}}$ [kWh/y]	4145	2694
SCOP [-]	2.86	4.37
$T_{\text{bivalent}}$ [°C]	-	-

	A++	A++
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	162	162
$P_{\text{rated}}$ [kW]	5	5
$Q_{\text{HE}}$ [kWh/y]	1449	1446
SCOP [-]	4.04	4.04
$T_{\text{bivalent}}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓