


ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

BW 08





55 °C

A++

35 °C

A++






43 dB


■ 7 ■ 8

■ **7** ■ **8**

■ 7 ■ 8

kW kW





- dB

2015

811/2013

BW 08

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	136	180
P_{rated} [kW]	7	8
Q_{HE} [kWh/y]	4513	3366
SCOP [-]	3.39	4.49
$T_{bivalent}$ [°C]	-	-

	A+	A++
Energy class	A+	A++
η [%]	120	184
P_{rated} [kW]	7	8
Q_{HE} [kWh/y]	6259	4058
SCOP [-]	2.99	4.59
$T_{bivalent}$ [°C]	-	-

	A++	A++
Energy class	A++	A++
η [%]	174	175
P_{rated} [kW]	7	8
Q_{HE} [kWh/y]	2181	2177
SCOP [-]	4.36	4.37
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓