


# ENERG


енергия - ενεργεια

Y IJA

IE IA




## BW 13




55 °C


A++



A++




A++




35 °C


A++




A+




A




B




C




D




E




F



G





**44** dB

■ 12

■ **12**

■ 12


kW

■ 13

■ **13**

■ 13

kW



2015

811/2013

### BW 13

### ErP Data

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	135	179
$P_{rated}$ [kW]	12	13
$Q_{HE}$ [kWh/y]	8009	5972
SCOP [-]	3.37	4.48
$T_{bivalent}$ [°C]	-10	-

	A+	A++
Energy class	<b>A+</b>	<b>A++</b>
$\eta$ [%]	118	181
$P_{rated}$ [kW]	12	13
$Q_{HE}$ [kWh/y]	11106	7198
SCOP [-]	2.94	4.52
$T_{bivalent}$ [°C]	-10	-

	A++	A++
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	176	176
$P_{rated}$ [kW]	12	13
$Q_{HE}$ [kWh/y]	3870	3862
SCOP [-]	4.40	4.41
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓