

ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK BW 05 Block

55 °C 35 °C

A++ **A++**

43 dB

- dB

5 kW 5 kW

2015 811/2013

BW 05 Block

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	128	168
P_{rated} [kW]	5	5
Q_{HE} [kWh/y]	2992	2236
SCOP [-]	3.20	4.21
$T_{bivalent}$ [°C]	-	-

	A+	A++
Energy class	A+	A++
η [%]	114	175
P_{rated} [kW]	5	5
Q_{HE} [kWh/y]	4145	2694
SCOP [-]	2.86	4.37
$T_{bivalent}$ [°C]	-	-

	A++	A++
Energy class	A++	A++
η [%]	162	162
P_{rated} [kW]	5	5
Q_{HE} [kWh/y]	1449	1446
SCOP [-]	4.04	4.04
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓