



ENERG

енергия - ενεργεια

Y IJA
IE IA



TBW 50





55 °C

A++

35 °C

A++






53 dB

■ 48 ■ 52

■ **48** ■ **52**

■ 48 ■ 52

kW kW



2015
811/2013

TBW 50

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	142	191
P_{rated} [kW]	48	52
Q_{HE} [kWh/y]	29759	22205
SCOP [-]	3.56	4.77
$T_{bivalent}$ [°C]	-8	-10

	A+	A++
Energy class	A+	A++
η [%]	123	190
P_{rated} [kW]	48	52
Q_{HE} [kWh/y]	41269	26776
SCOP [-]	3.08	4.74
$T_{bivalent}$ [°C]	-8	-10

	A++	A++
Energy class	A++	A++
η [%]	190	190
P_{rated} [kW]	48	52
Q_{HE} [kWh/y]	14389	14360
SCOP [-]	4.74	4.75
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓