



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TBW 90



55 °C

35 °C



**A++**

**A++**



57 dB



- dB

■ 84  
■ **84**  
■ 84  
kW

■ 89  
■ **89**  
■ 89  
kW



2015

811/2013

**TBW 90**

**ErP Data**

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 143        | 191        |
| $P_{rated}$ [kW]    | 84         | 89         |
| $Q_{HE}$ [kWh/y]    | 51560      | 38472      |
| SCOP [-]            | 3.57       | 4.78       |
| $T_{bivalent}$ [°C] | -8         | -10        |

|                     | A+        | A++        |
|---------------------|-----------|------------|
| Energy class        | <b>A+</b> | <b>A++</b> |
| $\eta$ [%]          | 123       | 190        |
| $P_{rated}$ [kW]    | 84        | 89         |
| $Q_{HE}$ [kWh/y]    | 71500     | 46390      |
| SCOP [-]            | 3.08      | 4.74       |
| $T_{bivalent}$ [°C] | -8        | -10        |

|                     | A++        | A++        |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 190        | 191        |
| $P_{rated}$ [kW]    | 84         | 89         |
| $Q_{HE}$ [kWh/y]    | 24930      | 24879      |
| SCOP [-]            | 4.76       | 4.77       |
| $T_{bivalent}$ [°C] | -          | -          |

CONTROLLER



|            |           |        |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |