



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

WW 07 EVI



55 °C

35 °C



**A++**

**A++**



44 dB



- dB

■ 6  
■ **6**  
■ 6  
kW

■ 7  
■ **7**  
■ 7  
kW



2015

811/2013

**WW 07 EVI**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	166	214
$P_{rated}$ [kW]	6	7
$Q_{HE}$ [kWh/y]	3210	2450
SCOP [-]	4.15	5.36
$T_{bivalent}$ [°C]	-10	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	150	221
$P_{rated}$ [kW]	6	7
$Q_{HE}$ [kWh/y]	4396	2961
SCOP [-]	3.75	5.53
$T_{bivalent}$ [°C]	-10	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	206	207
$P_{rated}$ [kW]	6	7
$Q_{HE}$ [kWh/y]	1588	1584
SCOP [-]	5.15	5.17
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓