



# ENERG

енергия - ενεργεια

Y IJA
IE IA



## WW 10 EVI





55 °C

**A++**


35 °C

**A++**





**44 dB**



■ 9    ■ 10  
■ **9**    ■ **10**  
■ 9    ■ 10  
kW    kW

2015
811/2013

### WW 10 EVI

### ErP Data

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	166	215
$P_{rated}$ [kW]	9	10
$Q_{HE}$ [kWh/y]	4885	3729
SCOP [-]	4.14	5.38
$T_{bivalent}$ [°C]	-9	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	148	219
$P_{rated}$ [kW]	9	10
$Q_{HE}$ [kWh/y]	6689	4507
SCOP [-]	3.70	5.47
$T_{bivalent}$ [°C]	-9	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	209	210
$P_{rated}$ [kW]	9	10
$Q_{HE}$ [kWh/y]	2418	2412
SCOP [-]	5.23	5.24
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓