

**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**


WW 14 EVI


55 °C

**A++**

35 °C

**A++**






**45 dB**

■ 12    ■ 14

■ **12**    ■ **14**

■ 12    ■ 14

kW    kW



2015

811/2013

**WW 14 EVI**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	173	225
$P_{rated}$ [kW]	12	14
$Q_{HE}$ [kWh/y]	6550	4998
SCOP [-]	4.32	5.63
$T_{bivalent}$ [°C]	-8	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	153	227
$P_{rated}$ [kW]	12	14
$Q_{HE}$ [kWh/y]	8972	6042
SCOP [-]	3.83	5.67
$T_{bivalent}$ [°C]	-8	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	220	221
$P_{rated}$ [kW]	12	14
$Q_{HE}$ [kWh/y]	3240	3231
SCOP [-]	5.51	5.52
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓