




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

WW 60 EVI



55 °C

35 °C




**A++**

**A++**



**53** dB



- dB

■ 53  
■ **53**  
■ 53  
kW

■ 61  
■ **61**  
■ 61  
kW



2015

811/2013

**WW 60 EVI**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	176	230
$P_{rated}$ [kW]	53	61
$Q_{HE}$ [kWh/y]	28242	21546
SCOP [-]	4.40	5.76
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	154	228
$P_{rated}$ [kW]	53	61
$Q_{HE}$ [kWh/y]	38683	26053
SCOP [-]	3.85	5.71
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	229	229
$P_{rated}$ [kW]	53	61
$Q_{HE}$ [kWh/y]	13970	13934
SCOP [-]	5.72	5.73
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓