


ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

BW 06 EVI





55 °C

A++

35 °C

A++






44 dB

■ 6
■ **6**
■ 6

kW

■ 6
■ **6**
■ 6

kW



2015

811/2013

BW 06 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	140	174
P_{rated} [kW]	6	6
Q_{HE} [kWh/y]	3291	2631
SCOP [-]	3.51	4.35
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	128	179
P_{rated} [kW]	6	6
Q_{HE} [kWh/y]	4441	3171
SCOP [-]	3.21	4.48
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	168	168
P_{rated} [kW]	6	6
Q_{HE} [kWh/y]	1704	1702
SCOP [-]	4.19	4.20
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓