



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

BW 09 EVI



55 °C

35 °C



**A++**

**A++**



44 dB



- dB

■ 9  
■ **9**  
■ 9  
kW

■ 9  
■ **9**  
■ 9  
kW



2015

811/2013

**BW 09 EVI**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	146	181
$P_{rated}$ [kW]	9	9
$Q_{HE}$ [kWh/y]	4751	3802
SCOP [-]	3.64	4.52
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	132	184
$P_{rated}$ [kW]	9	9
$Q_{HE}$ [kWh/y]	6410	4583
SCOP [-]	3.30	4.60
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	176	176
$P_{rated}$ [kW]	9	9
$Q_{HE}$ [kWh/y]	2462	2459
SCOP [-]	4.40	4.41
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓