


# ENERG


енергия - ενεργεια

Y IJA

IE IA



## BW 11 EVI




55 °C


A++

A++

35 °C

A++







**45** dB

11  
**11**  
11  
kW

11  
**11**  
11  
kW



2015
811/2013

BW 11 EVI		ErP Data	
	55 °C	35 °C	
Energy class	<b>A++</b>	<b>A++</b>	
$\eta$ [%]	147	182	
$P_{rated}$ [kW]	11	11	
$Q_{HE}$ [kWh/y]	6112	4892	
SCOP [-]	3.67	4.56	
$T_{bivalent}$ [°C]	-	-	
Energy class	<b>A++</b>	<b>A++</b>	
$\eta$ [%]	132	184	
$P_{rated}$ [kW]	11	11	
$Q_{HE}$ [kWh/y]	8248	5897	
SCOP [-]	3.31	4.61	
$T_{bivalent}$ [°C]	-	-	
Energy class	<b>A++</b>	<b>A++</b>	
$\eta$ [%]	178	179	
$P_{rated}$ [kW]	11	11	
$Q_{HE}$ [kWh/y]	3169	3165	
SCOP [-]	4.46	4.47	
$T_{bivalent}$ [°C]	-	-	
CONTROLLER			
	+ QAA55/75	class VII	3.5% ↓
	- QAA55/75	class III	1.5% ↓