

**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

BW 19 EVI


55 °C

**A++**

35 °C


**A++**


A++	▶
A+	▶
A	▶
B	▶
C	▶
D	▶
E	▶
F	▶
G	▶



**47** dB

■	20	■	19
■	<b>20</b>	■	<b>19</b>
■	20	■	19
	kW		kW







- dB

2015

811/2013

BW 19 EVI		ErP Data		
		55 °C	35 °C	
Energy class		<b>A++</b>	<b>A++</b>	
$\eta$ [%]		148	185	
$P_{rated}$ [kW]		20	19	
$Q_{HE}$ [kWh/y]		10571	8460	
SCOP [-]		3.71	4.62	
$T_{bivalent}$ [°C]		-	-	
Energy class		<b>A++</b>	<b>A++</b>	
$\eta$ [%]		132	185	
$P_{rated}$ [kW]		20	19	
$Q_{HE}$ [kWh/y]		14266	10200	
SCOP [-]		3.31	4.63	
$T_{bivalent}$ [°C]		-	-	
Energy class		<b>A++</b>	<b>A++</b>	
$\eta$ [%]		182	182	
$P_{rated}$ [kW]		20	19	
$Q_{HE}$ [kWh/y]		5479	5473	
SCOP [-]		4.56	4.56	
$T_{bivalent}$ [°C]		-	-	
CONTROLLER	 	+ QAA55/75	class VII	3.5% ↓
		- QAA55/75	class III	1.5% ↓