



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK BW 24 EVI



	55 °C	35 °C
Energy class	A++	A++
η [%]	146	182
P_{rated} [kW]	25	24
Q_{HE} [kWh/y]	13657	10921
SCOP [-]	3.64	4.54
$T_{bivalent}$ [°C]	-	-




	55 °C	35 °C
Energy class	A++	A++
η [%]	130	182
P_{rated} [kW]	25	24
Q_{HE} [kWh/y]	18431	13161
SCOP [-]	3.24	4.54
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	180	180
P_{rated} [kW]	25	24
Q_{HE} [kWh/y]	7071	7062
SCOP [-]	4.49	4.50
$T_{bivalent}$ [°C]	-	-

47 dB

- dB

	55 °C	35 °C
Power [kW]	25	24



2015 811/2013

BW 24 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	146	182
P_{rated} [kW]	25	24
Q_{HE} [kWh/y]	13657	10921
SCOP [-]	3.64	4.54
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	130	182
P_{rated} [kW]	25	24
Q_{HE} [kWh/y]	18431	13161
SCOP [-]	3.24	4.54
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	180	180
P_{rated} [kW]	25	24
Q_{HE} [kWh/y]	7071	7062
SCOP [-]	4.49	4.50
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓