



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

BW 49 EVI



55 °C

35 °C




A++

A++



53 dB



- dB

■ 50
■ **50**
■ 50
kW

■ 49
■ **49**
■ 49
kW



2015

811/2013

BW 49 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	150	187
P_{rated} [kW]	50	49
Q_{HE} [kWh/y]	26964	21579
SCOP [-]	3.74	4.67
$T_{bivalent}$ [°C]	-	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	133	186
P_{rated} [kW]	50	49
Q_{HE} [kWh/y]	36383	26013
SCOP [-]	3.32	4.64
$T_{bivalent}$ [°C]	-	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	186	186
P_{rated} [kW]	50	49
Q_{HE} [kWh/y]	13971	13955
SCOP [-]	4.64	4.65
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓