



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

AW 40 EVI



55 °C

35 °C



A++

A++



54 dB



65 dB

■ 41
■ **47**
■ 58
kW

■ 41
■ **47**
■ 58
kW



2015

811/2013

AW 40 EVI

ErP Data

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 136 | 173 |
| P_{rated} [kW] | 47 | 47 |
| Q_{HE} [kWh/y] | 24368 | 19157 |
| SCOP [-] | 3.41 | 4.33 |
| $T_{bivalent}$ [°C] | -7 | -7 |

| | A+ | A++ |
|---------------------|-----------|------------|
| Energy class | A+ | A++ |
| η [%] | 113 | 154 |
| P_{rated} [kW] | 41 | 41 |
| Q_{HE} [kWh/y] | 35408 | 25952 |
| SCOP [-] | 2.82 | 3.84 |
| $T_{bivalent}$ [°C] | -7 | -7 |

| | A++ | A++ |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 207 | 208 |
| P_{rated} [kW] | 58 | 58 |
| Q_{HE} [kWh/y] | 10279 | 10261 |
| SCOP [-] | 5.18 | 5.19 |
| $T_{bivalent}$ [°C] | - | - |

CONTROLLER



| | | |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |