



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

WW 75 SHR



55 °C

35 °C



**A++**

**A++**



53 dB



- dB

40  
**40**  
40  
kW

46  
**46**  
46  
kW



2015

811/2013

**WW 75 SHR**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	176	230
$P_{rated}$ [kW]	40	46
$Q_{HE}$ [kWh/y]	21501	16404
SCOP [-]	4.39	5.75
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	154	228
$P_{rated}$ [kW]	40	46
$Q_{HE}$ [kWh/y]	29450	19834
SCOP [-]	3.85	5.71
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	228	228
$P_{rated}$ [kW]	40	46
$Q_{HE}$ [kWh/y]	10635	10608
SCOP [-]	5.70	5.71
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓