




ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

AiWa 08 EVI Block



55 °C

35 °C



A++ **A++**



44 dB



45 dB

■ 8	■ 8
■ 9	■ 9
■ 12	■ 12
kW	kW



2015

811/2013

AiWa 08 EVI Block

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	127	160
P_{rated} [kW]	9	9
Q_{HE} [kWh/y]	5108	4015
SCOP [-]	3.18	4.01
$T_{bivalent}$ [°C]	-8	-8

	A+	A++
Energy class	A+	A++
η [%]	107	146
P_{rated} [kW]	8	8
Q_{HE} [kWh/y]	7415	5428
SCOP [-]	2.67	3.64
$T_{bivalent}$ [°C]	-8	-8

	A++	A++
Energy class	A++	A++
η [%]	186	187
P_{rated} [kW]	12	12
Q_{HE} [kWh/y]	2156	2153
SCOP [-]	4.66	4.67
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓