



# ENERG

енергия - ενεργεια

Y IJA
IE IA



## AiWa 08 EVI L





55 °C

**A++**


35 °C

**A++**





- dB



**54** dB

■ 8

■ **9**

■ 12


kW

■ 8

■ **9**



■ 12

kW



2015

811/2013

AiWa 08 EVI L		ErP Data		
	55 °C	35 °C		
Energy class	<b>A++</b>	<b>A++</b>		
$\eta$ [%]	127	160		
$P_{rated}$ [kW]	9	9		
$Q_{HE}$ [kWh/y]	5108	4015		
SCOP [-]	3.18	4.01		
$T_{bivalent}$ [°C]	-8	-8		
Energy class	<b>A+</b>	<b>A++</b>		
$\eta$ [%]	107	146		
$P_{rated}$ [kW]	8	8		
$Q_{HE}$ [kWh/y]	7415	5428		
SCOP [-]	2.67	3.64		
$T_{bivalent}$ [°C]	-8	-8		
Energy class	<b>A++</b>	<b>A++</b>		
$\eta$ [%]	186	187		
$P_{rated}$ [kW]	12	12		
$Q_{HE}$ [kWh/y]	2156	2153		
SCOP [-]	4.66	4.67		
$T_{bivalent}$ [°C]	-	-		
CONTROLLER		+ QAA55/75	class VII	3.5% ↓
		- QAA55/75	class III	1.5% ↓