



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TBW 50i



55 °C

35 °C




**A++**

**A++**



54 dB



- dB

■ 48  
■ **48**  
■ 48  
kW

■ 51  
■ **51**  
■ 51  
kW



2015

811/2013

**TBW 50i**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	142	191
$P_{rated}$ [kW]	48	51
$Q_{HE}$ [kWh/y]	29471	21990
SCOP [-]	3.56	4.77
$T_{bivalent}$ [°C]	-8	-10

	A+	A++
Energy class	<b>A+</b>	<b>A++</b>
$\eta$ [%]	123	190
$P_{rated}$ [kW]	48	51
$Q_{HE}$ [kWh/y]	40870	26517
SCOP [-]	3.08	4.74
$T_{bivalent}$ [°C]	-8	-10

	A++	A++
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	190	190
$P_{rated}$ [kW]	48	51
$Q_{HE}$ [kWh/y]	14249	14221
SCOP [-]	4.74	4.75
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓