




**ENERG** Y IJA  
енергия - ενεργεια IE IA


**WAMAK**

AW 23 EVI



55 °C

35 °C




**A++**

**A**



51 dB



67 dB

■ 22  
■ **25**  
■ 31  
kW

■ 22  
■ **25**  
■ 31  
kW



2019

811/2013

**AW 23 EVI**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A</b>	<b>A++</b>
$\eta$ [%]	120	152
$P_{rated}$ [kW]	25	25
$Q_{HE}$ [kWh/y]	14624	11488
SCOP [-]	3.01	3.81
$T_{bivalent}$ [°C]	0	0

	D	A+
Energy class	<b>D</b>	<b>A+</b>
$\eta$ [%]	100	136
$P_{rated}$ [kW]	22	22
$Q_{HE}$ [kWh/y]	21194	15486
SCOP [-]	2.49	3.41
$T_{bivalent}$ [°C]	0	0

	A+++	A+++
Energy class	<b>A+++</b>	<b>A+++</b>
$\eta$ [%]	181	182
$P_{rated}$ [kW]	31	31
$Q_{HE}$ [kWh/y]	6174	6163
SCOP [-]	4.53	4.54
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓